

Received & Inspected

OCT 11 2017

FCC Mail Room

**CALVARY CHAPEL OF TWIN FALLS, Inc.**

PO Box 391

4002 N. 3300 E.

Twin Falls, ID 83303

Ph(208)734-6633 Ext. 206 – Fax (208)736-1958

loism@csnradio.com

2017 OCT 12 A 10: 48

October 6, 2017

Office of the Secretary

Attn: Chief, Audio Division, Media Bureau

Federal Communications Commission

445 12<sup>th</sup> Street, SW


Washington, DC 20554

**ATTENTION: FM Branch, Mass Media Bureau**  
**REFERENCE: KGFJ BELT, MT**  
**Facility ID No: 172645 / 10 day Notification**

Dear Staff:

Calvary Chapel of Twin Falls, Inc.(CCTF) respectfully notifies the Commission that KGFJ Belt, Montana, Facility ID 172645 is operating at a low power since September 27, 2017, when STAR Radio personnel visited the site and forgot to turn the air conditioner back on before they left the site. Because of the heat in the building KGJF's transmitter has folded back and is operating at 30.4 watts, with a little variation. STAR Radio is scheduled to send personnel to the site to correct the problem in the near future. However, if normal operations have not resumed within the specified 30 days, an STA request to continue to operate at reduced power, will be electronically filed.

Sincerely,



Lois Mills

Applications Technician

Calvary Chapel of Twin Falls, Inc.